

Spare parts

- Spare parts
- Autofocus infrared sensor

Technical data

Software settings

Afterflow period	2 s ± 1 s (1/2/3/4/5/6/7/8 s)
Automatic flush	off (off/12/24/48/72 h)
Automatic flush period	30 s (10/30/60/120/180/240/300/600 s)
Max. flow period	120 s (10/30/60/120/300 s)

Regulations

EMC Directive	C E 2004/108/EY
Protection class	IP 67

