



## SWEDISH TYPE APPROVAL 1684 WITH DECISION ON PRODUCTION CONTROL

### Holder: Oras Ltd

P.O. Box 40, 26101 Rauma, Finland

Phone: +46 21 81 61 31

E- mail: info.sweden@oras.com

Homepage: www.oras.com

### Oras Clinica, wall mounted touchless faucets

#### Product description

Touchless faucets in brass (EN 15091) with cover plate triple sealed for concealed installation.

The faucets includes litter filters, non-return valves, safety lock against scalding, thermostatic cartridge for automatic temperature control and autofocus infrared sensor.

#### Intended use

Electronic mixer, for hot and cold tap water, intended to be used in washbasins and showers, primarily in the healthcare and care sector.

#### Scope

Models:

5670U, 5671U, 5672U

#### Approval

The products meet the requirements of Chapter 8, Section 4, of the "Planning and Building Act" (PBA) regarding the technical characteristics of construction works, protection regarding hygiene, health and the environment, depending on, that what is stated in this approval is followed. The products are approved according to the following section(s) of "Boverket's Building Regulations" (BBR):

Construction products with assessed properties	1:4
Tap water installations	6:62 (first sentence and paragraph 2 and general recommendations)
Tap water flow	6:623 (first sentence)
Backflow	6:624
Design	6:625 (paragraph 1 and 4)

#### Marking

Marking must be affixed on the product or, if there are special reasons, on the packaging or the delivery note. Marking shall indicate the following information:

Holder:

Product name, and relevant article number:

Production site:

Traceability to the production:

The registered trademark of Boverket No 241 217:

Certification Body:

Accreditation number:

Type Approval No:

Inspection Body:

Oras Ltd

Product name (article number)

Oras Oy,

Rauma, Finland

(e.g. yyyy-mm-dd or batchnumber)



Kiwa Sverige AB

1913

1684

Kiwa Sverige AB



CERTIFIKAT

#### Kiwa Sverige AB

Campus Gräsvik 1  
SE-371 75 Karlskrona  
Sweden

Tel +46 (0)455-30 56 00

Fax +46 (0)455-104 36

[se.bygg@kiwa.com](mailto:se.bygg@kiwa.com)

[www.kiwa.se](http://www.kiwa.se)



Accred. no. 1913  
Certification of  
Products  
ISO/IEC 17065

**Control**

The manufacturers' continuing internal control is combined with surveillance inspections conducted by an accredited Inspection Body.

Inspection Body: **Kiwa Sverige AB**

Inspection agreement: **1168/17**

Factory production control shall be carried out in accordance with the instructions for control, dated 2019-04-05.

During inspection at the construction site, the building proprietor must verify the identity of the product by means of the marking. Furthermore, the building proprietor must ensure that the correct products are delivered and that they are installed in accordance with the manufacturer's instructions in the accompanying documents. It must also be verified that the product is accompanied by a manufacturer's declaration that certifies that production has been carried out in accordance with the documents that formed the basis for this type approval.

The validity of the Swedish Type Approval also implies that the factory production control is carried out according to agreement **1168/17** and that the holder annually fulfils the requirement in "Boverket's regulations and general recommendations for type approval", BFS 2013:6, § 5 (TYP 7), on continuing internal control. The holder shall annually, at the latest on the 15th of December, report to Kiwa Certification at the e-mail address [se.annualreporting@kiwa.com](mailto:se.annualreporting@kiwa.com) about continuing surveillance.

**Associated documents**

Oras Clinica - Installation and maintenance guide 943433-04-20

**The assessment basis for the approval**

Test reports EUFI29-20002097-T1, EUFI29-20002034-T1 and EUFI29-20000931-T1 (Eurofins)

Assessment report 865/20 (Kiwa Sverige AB)

**Comments**

The faucets have been tested according to EN 15091:2013.

Acoustic group I for all models.

**Models:**

5670U\*, 6 V battery, shower faucet

5671U\*, 6 V battery, wash basin faucet, detachable swivel spout 100 mm

5672U\*, 6 V battery, wash basin faucet, detachable swivel spout 200 mm

\*) Bluetooth models

The Type approval is valid provided that the product shall neither be CE marked according to the Construction Product Regulation (EU) No 305/2011 (CPR), nor has it been suspended or withdrawn by Kiwa Sverige AB.

Date of decision: 2020-11-24

Registration number: 0865/20

Valid until: 2025-11-23

Previous registration number: -



**Deo Yamabo**



**Bengt-Olov Andin**